Emergency Shutdown Procedure

1. Turn off UPS by pushing power button on front panel



2. Pull both 20A power cords from the wall



Fed from:

413PP23BR38

413PP23BR40

Contact:

Mike Crisler cell: (630) 276-8705, work: (630) 840-4099

Jeter Hall cell: (801) 735-7433, work: (630) 840-6660